



Product Service

# Attestation of Conformity

No. D6 108819 0010 Rev. 00

**Holder of Attestation:** **ALP POMPA TEKNOLOJILERI TICARET SANAYI A.S.**

Dudullu OSB 2.Cadde No:14  
34775 Umraniye Istanbul  
TÜRKIYE

**Product:** **Circulation pump**  
**Model(s):** **ECP32-120F 220, ECP32-120F 220N**

**Parameters:**

|                       |                           |
|-----------------------|---------------------------|
| Rated voltage:        | 230V~                     |
| Rated frequency:      | 50/60Hz                   |
| Rated input power:    | 329W Max.                 |
| Protection class:     | I                         |
| Degree of protection: | IP44                      |
| Declared head:        | 12 m Max.                 |
| Declared flow:        | 17 m <sup>3</sup> /h Max. |
| Declared EEI:         | Less than 0.23            |

Implementation Measure EC Regulation  
No 641/2009: 2009-07-22 amended by  
(EU) 622/2012:2012-07-11, (EU) 2016/2282: 2016-11-30,  
(EU) 2019/1781:2019-10-01  
Stage 2 (2015-08-01)

**Brand Name:** **ETNA**

**Tested according to:** PPP 11093E:2019  
EN 16297-1:2012  
EN 16297-2:2012  
EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the particular sample and its technical documentation submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 871282304806-00

**Date,** 2023-11-20

( Lucy (Jianying) Lu )



Product Service

# Attestation of Conformity

No. D6 108819 0011 Rev. 00

**Holder of Attestation:** **ALP POMPA TEKNOLOJILERI TICARET SANAYI A.S.**

Dudullu OSB 2.Cadde No:14  
34775 Umraniye Istanbul  
TÜRKIYE

**Product:** **Circulation pump**  
**Model(s):** **ECP40-120F 250, ECP40-120F 250N**

**Parameters:**

|                       |                           |
|-----------------------|---------------------------|
| Rated voltage:        | 230V~                     |
| Rated frequency:      | 50/60Hz                   |
| Rated input power:    | 463W Max.                 |
| Protection class:     | I                         |
| Degree of protection: | IP44                      |
| Declared head:        | 12m Max.                  |
| Declared flow:        | 24 m <sup>3</sup> /h Max. |
| Declared EEI:         | Less than 0.23            |

Implementation Measure EC Regulation  
No 641/2009: 2009-07-22 amended by  
(EU) 622/2012:2012-07-11, (EU) 2016/2282: 2016-11-30,  
(EU) 2019/1781:2019-10-01  
Stage 2 (2015-08-01)

**Brand Name:** **ETNA**

**Tested according to:** PPP 11093E:2019  
EN 16297-1:2012  
EN 16297-2:2012  
EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the particular sample and its technical documentation submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 871282304807-00

**Date,** 2023-11-20

( Lucy (Jianying) Lu )



Product Service

# Attestation of Conformity

No. D6 108819 0012 Rev. 00

**Holder of  
Attestation:****ALP POMPA TEKNOLOJILERI  
TICARET SANAYI A.S.**Dudullu OSB 2.Cadde No:14  
34775 Umraniye Istanbul  
TÜRKIYE**Product:  
Model(s):****Circulation pump  
ECP40-150F 250, ECP40-150F 250N****Parameters:**

|                       |                             |
|-----------------------|-----------------------------|
| Rated voltage:        | 230V~                       |
| Rated frequency:      | 50/60Hz                     |
| Rated input power:    | 615W Max.                   |
| Protection class:     | I                           |
| Degree of protection: | IP44                        |
| Declared head:        | 15m Max.                    |
| Declared flow:        | 26.2 m <sup>3</sup> /h Max. |
| Declared EEI:         | Less than 0.23              |

Implementation Measure EC Regulation  
No 641/2009: 2009-07-22 amended by  
(EU) 622/2012:2012-07-11, (EU) 2016/2282: 2016-11-30,  
(EU) 2019/1781:2019-10-01  
Stage 2 (2015-08-01)**Brand Name:****ETNA****Tested  
according to:**PPP 11093E:2019  
EN 16297-1:2012  
EN 16297-2:2012  
EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the particular sample and its technical documentation submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:**

871282304808-00

**Date,** 2023-11-20

( Lucy (Jianying) Lu )



Product Service

# Attestation of Conformity

No. D6 108819 0019 Rev. 00

**Holder of Attestation:** **ALP POMPA TEKNOLOJILERI TICARET SANAYI A.S.**

Dudullu OSB 2.Cadde No:14  
34775 Umraniye Istanbul  
TÜRKIYE

**Product:** **Circulation pump**  
**Model(s):** **ECP50-80F 240, ECP50-80F 240N**

**Parameters:**

|                       |                           |
|-----------------------|---------------------------|
| Rated voltage:        | 230V~                     |
| Rated frequency:      | 50/60Hz                   |
| Rated input power:    | 331W Max.                 |
| Protection class:     | I                         |
| Degree of protection: | IP44                      |
| Declared head:        | 8 m Max.                  |
| Declared flow:        | 27 m <sup>3</sup> /h Max. |
| Declared EEI:         | ≤0.23                     |

Implementation Measure EC Regulation  
No 641/2009:2009-07-22 amended by  
(EU) 622/2012:2012-07-11, (EU) 2016/2282:2016-11-30,  
(EU) 2019/1781:2019-10-01  
Stage 2 (2015-08-01)

**Brand Name:** **ETNA**

**Tested according to:** PPP 11093E:2019  
EN 16297-1:2012  
EN 16297-2:2012  
EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the particular sample and its technical documentation submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 871282405002-00

**Date,** 2024-05-21

( Lucy (Jianying) Lu )



Product Service

# Attestation of Conformity

No. D6 108819 0013 Rev. 00

**Holder of Attestation:** **ALP POMPA TEKNOLOJILERI TICARET SANAYI A.S.**

Dudullu OSB 2.Cadde No:14  
34775 Umraniye Istanbul  
TÜRKIYE

**Product:** **Circulation pump**  
**Model(s):** **ECP50-180F 280, ECP50-180F 280N**

**Parameters:**

|                       |                             |
|-----------------------|-----------------------------|
| Rated voltage:        | 230V~                       |
| Rated frequency:      | 50/60Hz                     |
| Rated input power:    | 769W Max.                   |
| Protection class:     | I                           |
| Degree of protection: | IP44                        |
| Declared head:        | 18m Max.                    |
| Declared flow:        | 37.5 m <sup>3</sup> /h Max. |
| Declared EEI:         | Less than 0.23              |

Implementation Measure EC Regulation  
No 641/2009: 2009-07-22 amended by  
(EU) 622/2012:2012-07-11, (EU) 2016/2282: 2016-11-30,  
(EU) 2019/1781:2019-10-01  
Stage 2 (2015-08-01)

**Brand Name:** **ETNA**

**Tested according to:** PPP 11093E:2019  
EN 16297-1:2012  
EN 16297-2:2012  
EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the particular sample and its technical documentation submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 871282304809-00

**Date,** 2023-11-20

( Lucy (Jianying) Lu )



Product Service

# Attestation of Conformity

No. D6 108819 0018 Rev. 00

**Holder of  
Attestation:****ALP POMPA TEKNOLOJILERI  
TICARET SANAYI A.S.**Dudullu OSB 2.Cadde No:14  
34775 Umraniye Istanbul  
TÜRKIYE**Product:****Circulation pump****Model(s):****ECP50-120F 280, ECP50-120F 280N****Parameters:**

|                       |                          |
|-----------------------|--------------------------|
| Rated voltage:        | 230V~                    |
| Rated frequency:      | 50/60Hz                  |
| Rated input power:    | 533W Max.                |
| Protection class:     | I                        |
| Degree of protection: | IP44                     |
| Declared head:        | 12m Max.                 |
| Declared flow:        | 33m <sup>3</sup> /h Max. |
| Declared EEI:         | ≤0.23                    |

Implementation Measure EC Regulation  
No 641/2009: 2009-07-22 amended by  
(EU) 622/2012:2012-07-11, (EU) 2016/2282: 2016-11-30,  
(EU) 2019/1781:2019-10-01  
Stage 2 (2015-08-01)**Brand Name:****ETNA****Tested  
according to:**PPP 11093E:2019  
EN 16297-1:2012  
EN 16297-2:2012  
EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the particular sample and its technical documentation submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:**

871282405001-00

**Date,** 2024-05-21

( Lucy (Jianying) Lu )



Product Service

# Attestation of Conformity

No. D6 108819 0020 Rev. 00

**Holder of  
Attestation:****ALP POMPA TEKNOLOJILERI  
TICARET SANAYI A.S.**Dudullu OSB 2.Cadde No:14  
34775 Umraniye Istanbul  
TÜRKIYE**Product:  
Model(s):****Circulation pump  
ECP65-100F 340, ECP65-100F 340N****Parameters:**

|                       |                           |
|-----------------------|---------------------------|
| Rated voltage:        | 230V~                     |
| Rated frequency:      | 50/60Hz                   |
| Rated input power:    | 619W Max.                 |
| Protection class:     | I                         |
| Degree of protection: | IP44                      |
| Declared head:        | 10 m Max.                 |
| Declared flow:        | 44 m <sup>3</sup> /h Max. |
| Declared EEI:         | ≤0.23                     |

Implementation Measure EC Regulation  
No 641/2009:2009-07-22 amended by  
(EU) 622/2012:2012-07-11, (EU) 2016/2282:2016-11-30,  
(EU) 2019/1781:2019-10-01  
Stage 2 (2015-08-01)

**Brand Name:****ETNA****Tested  
according to:**PPP 11093E:2019  
EN 16297-1:2012  
EN 16297-2:2012  
EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the particular sample and its technical documentation submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:**

871282405003-00

**Date,** 2024-05-21

( Lucy (Jianying) Lu )



Product Service

# Attestation of Conformity

No. D6 108819 0014 Rev. 00

**Holder of Attestation:** **ALP POMPA TEKNOLOJILERI TICARET SANAYI A.S.**

Dudullu OSB 2.Cadde No:14  
34775 Umraniye Istanbul  
TÜRKIYE

**Product:** **Circulation pump**  
**Model(s):** **ECP65-150F 340, ECP65-150F 340N**  
**Parameters:**

Rated voltage: 230V~  
Rated frequency: 50/60Hz  
Rated input power: 1263W Max.  
Protection class: I  
Degree of protection: IP44  
Declared head: 15m Max.  
Declared flow: 56 m<sup>3</sup>/h Max.  
Declared EEI: Less than 0.23

Implementation Measure EC Regulation  
No 641/2009: 2009-07-22 amended by  
(EU) 622/2012:2012-07-11, (EU) 2016/2282: 2016-11-30,  
(EU) 2019/1781:2019-10-01  
Stage 2 (2015-08-01)

**Brand Name:** **ETNA**  
**Tested according to:** PPP 11093E:2019  
EN 16297-1:2012  
EN 16297-2:2012  
EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the particular sample and its technical documentation submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 871282304810-00

**Date,** 2023-11-20

( Lucy (Jianying) Lu )





Product Service

# Attestation of Conformity

No. D6 108819 0021 Rev. 00

|                               |   |
|-------------------------------|---|
| <b>Holder of Attestation:</b> | <b>ALP POMPA TEKNOLOJILERI<br/>TICARET SANAYI A.S.</b><br>Dudullu OSB 2.Cadde No:14<br>34775 Umraniye Istanbul<br>TÜRKIYE   |
| <b>Product:<br/>Model(s):</b> | <b>Circulation pump<br/>ECP80-120F 360, ECP80-120F 360N</b>   |
| <b>Parameters:</b>            | Rated voltage: 230V~<br>Rated frequency: 50/60Hz<br>Rated input power: 1277W Max.<br>Protection class: I<br>Degree of protection: IP44<br>Declared head: 12 m Max.<br>Declared flow: 60.1 m <sup>3</sup> /h Max.<br>Declared EEI: ≤0.23<br>Implementation Measure EC Regulation<br>No 641/2009:2009-07-22 amended by<br>(EU) 622/2012:2012-07-11, (EU) 2016/2282:2016-11-30,<br>(EU) 2019/1781:2019-10-01<br>Stage 2 (2015-08-01) |
| <b>Brand Name:</b>            | <b>ETNA</b>   |
| <b>Tested according to:</b>   | PPP 11093E:2019<br>EN 16297-1:2012<br>EN 16297-2:2012<br>EN 16297-3:2012  |

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the particular sample and its technical documentation submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

Test report no.: 871282405004-00

Date, 2024-05-21

( Lucy (Jianying) Lu )